

Licensee: McDonald's Australia Limited
 Premises: 23 Maitland Rd, Hexham NSW 2322
 Licence: 329
 Monitoring Frequency: Monthly



<https://app.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=329&id=329&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued>

McDonalds Hexham: Water Testing Results - September 2025 to August 2026 from Point 2 as listed in EPA Licence

Parameter	Unit of Measurement	Sep-25	Oct-25	Nov-25	Dec-25	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26
Sample Date		25/09/2025	22/10/2025	25/11/2025	12/12/2025	15/01/2026	19/02/2026	19/03/2026					
Date Data was Obtained		1/10/2025	28/10/2025	2/12/2025	23/12/2025	23/01/2026	4/03/2026	31/03/2026					
Published Date		19/10/2025	2/11/2025	3/12/2025	2/01/2026	5/02/2026	6/03/2026	01/04/2-26					
Biochemical Oxygen Demand	Milligrams per litre	2.00	2.00	2.00	2.00	2.00	2.00	2.00					
Enterococci	cfu per 100 mL	10.00	10.00	10.00	10.00	1.00	10.00	2.00					
Faecal Coliforms	cfu per 100 mL	10.00	10.00	10.00	2.00	4.00	10.00	2.00					
MBAS	Milligrams per litre	0.20	0.20	0.10	0.10	0.10	0.10	0.10					
Nitrogen (ammonia)	Milligrams per litre	0.02	0.03	0.01	0.03	0.08	0.04	0.01					
Nitrogen (total)	Milligrams per litre	23.20	14.90	23.70	17.50	23.30	18.70	16.20					
Oil and Grease	Milligrams per litre	5.00	5.00	5.00	5.00	5.00	5.00	10.00					
pH	pH	7.03	6.90	6.66	7.13	6.90	6.95	7.10					
Phosphorus (total)	Milligrams per litre	1.45	1.17	2.71	1.09	4.96	6.94	6.22					
Suspended Solids	Milligrams per litre	7.00	5.00	5.00	7.00	12.00	6.00	5.00					

EPA Licence L3 Concentration Limits

Parameter	Units	Concentration Limits
Oil & Grease	milligrams per litre	10
pH	pH	6.5 - 8.5
Faecal Coliforms	cfu per 100 mL	100
Suspended Solids	milligrams per litre	30
Biochemical Oxygen Demand]	milligrams per litre	20
Enterococci	cfu per 100 mL	100

Monitoring and Discharge Points per EPA Licence

Point 2: M1 - Monitoring Point on grassed area of the land to the west of the site.
 Point 3: D1 - Discharge of treated water is piped under Maitland Road and into Hexham River

Reasons for Limits being Exceeded