

Licensee: McDonald's Australia Limited
Premises: 23 Maitland Rd, Hexham NSW 2322
Licence: 329

Monitoring Frequency: Monthly

<https://app.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=329&id=329&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued>



McDonalds Hexham: Water Testing Results - September 2025 to August 2026 from Point 2 as listed in EPA Licence

Parameter	Unit of Measurement	Sep-25	Oct-25	Nov-25	Dec-25	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26
Sample Date		25/09/2025	22/10/2025	25/11/2025	12/12/2025	15/01/2026	19/02/2026	19/03/2026	20/04/2026	20/05/2026	10/06/2026	8/07/2026	
Date Data was Obtained		1/10/2025	28/10/2025	2/12/2025	23/12/2025	23/01/2026	4/03/2026	31/03/2026	29/04/2026	29/05/2026	23/06/2026	21/07/2026	
Published Date		19/10/2025	2/11/2025	3/12/2025	2/01/2026	5/02/2026	6/03/2026	01/04/2-26	7/05/2026	13/06/2026	6/07/2026	2/08/2026	
Biochemical Oxygen Demand	Milligrams per litre	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00	
Enterococci	cfu per 100 mL	10.00	10.00	10.00	10.00	1.00	10.00	2.00	10.00	10.00	10.00	10.00	
Faecal Coliforms	cfu per 100 mL	10.00	10.00	10.00	2.00	4.00	10.00	2.00	100.00	10.00	10.00	10.00	
MBAS	Milligrams per litre	0.20	0.20	0.10	0.10	0.10	0.10	0.10	0.20	0.10	0.10	0.20	
Nitrogen (ammonia)	Milligrams per litre	0.02	0.03	0.01	0.03	0.08	0.04	0.01	0.05	0.07	0.05	0.06	
Nitrogen (total)	Milligrams per litre	23.20	14.90	23.70	17.50	23.30	18.70	16.20	25.10	16.90	21.00	25.50	
Oil and Grease	Milligrams per litre	5.00	5.00	5.00	5.00	5.00	5.00	10.00	5.00	5.00	5.00	5.00	
pH	pH	7.03	6.90	6.66	7.13	6.90	6.95	7.10	6.97	7.19	7.02	7.22	
Phosphorus (total)	Milligrams per litre	1.45	1.17	2.71	1.09	4.96	6.94	6.22	8.63	4.87	4.09	4.31	
Suspended Solids	Milligrams per litre	7.00	5.00	5.00	7.00	12.00	6.00	5.00	11.00	33.00	12.00	16.00	

EPA Licence L3 Concentration Limits

Parameter	Units	Concentration Limits
Oil & Grease	milligrams per litre	10
pH	pH	6.5 - 8.5
Faecal Coliforms	cfu per 100 mL	100
Suspended Solids	milligrams per litre	30
Biochemical Oxygen Demand]	milligrams per litre	20
Enterococci	cfu per 100 mL	100

Monitoring and Discharge Points per EPA Licence

Point 2: M1 - Monitoring Point on grassed area of the land to the west of the site.

Point 3: D1 - Discharge of treated water is piped under Maitland Road and into Hexham River

Reasons for Limits being Exceeded