

Licensee: McDonald's Australia Limited
Premises: 23 Maitland Rd, Hexham NSW 2322
Licence: 329
Monitoring Frequency: Monthly

<https://app.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=329&id=329&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued>

McDonalds Hexham: Water Testing Results - September 2025 to August 2026 from Point 2 as listed in EPA Licence

Parameter	Unit of Measurement	# of Samples Required	# of Samples Collected/Analysed	Sep-25	Oct-25	Nov-25	Dec-25	Jan-26	Feb-26	Mar-26	Apr-26	May-26
Sample Date				25/09/2025	22/10/2025	25/11/2025	12/12/2025	15/01/2026	19/02/2026	19/03/2026	20/04/2026	20/05/2026
Date Data was Obtained				1/10/2025	28/10/2025	2/12/2025	23/12/2025	23/01/2026	4/03/2026	31/03/2026	29/04/2026	29/05/2026
Published Date				19/10/2025	2/11/2025	3/12/2025	2/01/2026	5/02/2026	6/03/2026	01/04/2-26	7/05/2026	13/06/2026
Biochemical Oxygen Demand	Milligrams per litre	1	1	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00
Enterococci	cfu per 100 mL	1	1	10.00	10.00	10.00	10.00	1.00	10.00	2.00	10.00	10.00
Faecal Coliforms	cfu per 100 mL	1	1	10.00	10.00	10.00	2.00	4.00	10.00	2.00	100.00	10.00
MBAS	Milligrams per litre	1	1	0.20	0.20	0.10	0.10	0.10	0.10	0.10	0.20	0.10
Nitrogen (ammonia)	Milligrams per litre	1	1	0.02	0.03	0.01	0.03	0.08	0.04	0.01	0.05	0.07
Nitrogen (total)	Milligrams per litre	1	1	23.20	14.90	23.70	17.50	23.30	18.70	16.20	25.10	16.90
Oil and Grease	Milligrams per litre	1	1	5.00	5.00	5.00	5.00	5.00	5.00	10.00	5.00	5.00
pH	pH	1	1	7.03	6.90	6.66	7.13	6.90	6.95	7.10	6.97	7.19
Phosphorus (total)	Milligrams per litre	1	1	1.45	1.17	2.71	1.09	4.96	6.94	6.22	8.63	4.87
Suspended Solids	Milligrams per litre	1	1	7.00	5.00	5.00	7.00	12.00	6.00	5.00	11.00	33.00

EPA Licence L3 Concentration Limits

Paramater	Units			Concentration Limits
Oil & Grease	milligrams per litre			10
pH	pH			6.5 - 8.5
Faecal Coliforms	cfu per 100 mL			100
Suspended Solids	milligrams per litre			30
Biochemical Oxygen Demand]	milligrams per litre			20
Enterococci	cfu per 100 mL			100

Monitoring and Discharge Points per EPA Licence

Point 2: M1 - Monitoring Point on grassed area of the land to the west of the silo
Point 3: D1 - Discharge of treated water is piped under Maitland Road and into

Reasons for Limits being Exceeded

May suspended solids 2026 - marginally exceeded. Lab suspected sampling



Jun-26	Jul-26	Aug-26
10/06/2026		
23/06/2026		
6/07/2026		
2.00		
10.00		
10.00		
0.10		
0.05		
21.00		
5.00		
7.02		
4.09		
12.00		

te.
Hexham River

g error.