Licensee: McDonald's Australia Limited
Premises: 23 Maitland Rd, Hexham NSW 2322
Licence: 329
Monitoring Frequency: Monthly
https://app.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=329&id=329&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued

McDonalds Hexham: Water Testing Results - September 2026 to August 2027 from Point 2 & 3 as listed in EPA Licence

Parameter	Unit of Measurement	Sep-26	Oct-26	Nov-26	Dec-26	Jan-27	Feb-27	Mar-27	Apr-27	May-27	Jun-27	Jul-27	Aug-27
Sample Date		14/09/2026	6/10/2026										
Date Data was Obtained		23/09/2026	28/10/2026										
Published Date		8/10/2026	3/11/2026										
Biochemical Oxygen Demand	Milligrams per litre	2.00	2.00										
Enterococci	cfu per 100 mL	1.00	1.00										
Faecal Coliforms	cfu per 100 mL	1.00	1.00										
MBAS	Milligrams per litre	0.10	0.10										
Nitrogen (ammonia)	Milligrams per litre	0.01	6.41										
Nitrogen (total)	Milligrams per litre	23.10	22.50										
Oil and Grease	Milligrams per litre	5.00	5.00										
pH	pH	6.95	7.25										
Phosphorus (total)	Milligrams per litre	3.45	10.60										
Suspended Solids	Milligrams per litre	5.00	10.00										

EPA Licence L3 Concentration Limits

Paramater	Units	Concentration Limits
Oil & Grease	milligrams per litre	10
pH	pH	6.5 - 8.5
Faecal Coliforms	cfu per 100 mL	100
Suspended Solids	milligrams per litre	30
Biochemical Oxygen Demand]	milligrams per litre	20
Enterococci	cfu per 100 mL	100

Monitoring and Discharge Points per EPA Licence

Point 2: M1 - Monitoring Point on grassed area of the land to the west of the site.
Point 3: D1 - Discharge of treated water is piped under Maitland Road and into Hexham River

Reasons for Limits being Exceeded